

Transmission and End-User Interconnection Requirements Effective Date: 1-12-24 Version: 8

REFERENCES		
FAC-001	IEEE C62.22	PRC-006
NERC EOP-003	MISO Transmission Planning Business Practices Manual BPM- 020	IEEE 519
FERC 715		

VERSION HISTORY

Current	Approval	Effective	Author	Changes
Version	Date	Date		
8	1/12/24	1/12/24	M. Dicks	Updated applicability language. Updated FAC-001 "qualified change" language. Updated references.
7	8/19/21	8/19/21	Ostrander	Changed Hoosier contact info
6	7/7/21	7/7/21	Ostrander	Administrative review. Updated titles and references.
5	12/28/18	12/31/18	Ostrander	Annual Update: Reviewed and revised to include changes to FAC-001-3. Added language for R3.3.
4	12/29/15	12/31/15	Fields	Annual update; Reviewed and revised to include language addressing changes in FAC-001-2
3	12/31/14	12/31/14	Taft	Updated to Standard Hoosier format and modified document
2	05/31/14	05/31/14	Taft	Modifications to clarify requirements and to align with NERC Standards wording
1	02/01/09	02/01/09	Hill	Initial Release
0	01/09/02	02/01/02	Hill	Original legacy procedure

Transmission and End-User Interconnection Requirements

HOOSIERENERGY RURAL ELECTRIC COOPERATIVE, INC.

14	Table	of Contents	
15	1.0 PUI	RPOSE	4
16	2.0 APF	PLICABILITY	4
17	3.0 HO	OSIER CONTACT	4
18 19 20	4.0 PRO INTERO AFFEC	OCEDURES FOR COORDINATED STUDIES OF NEW OR EXISTING CONNECTIONS WITH A QUALIFIED CHANGE AND THEIR IMPACTS ON TED SYSTEM(S) FAC-001-3 R3.1	. 5
21 22 23	5.0 PR OF AFF QUALIF	OCEDURES FOR NOTIFYING THOSE RESPONSIBLE FOR THE RELIABILIT FECTED SYSTEM(S) OF NEW OR EXISTING INTERCONNECTIONS WITH A FIED CHANGE FAC-001-4 R3 2	Y
24 25 26 27	6.0 PRO RELIAE WITH A METER	OCEDURES FOR CONFIRMING WITH THOSE RESPONSIBLE FOR THE BILITY OF AFFECTED SYSTEM(S) OF NEW OR TRANSMISSION FACILITIES A QUALIFIED CHANGE ARE WITHIN A BALANCING AUTHORITY AREA'S RED BOUNDARIES FAC-001-4 R3.3	3
28	7.0 DEI	FINITION OF QUALIFIED CHANGE	. 6
29	8.0 SYS	STEM IMPACT STUDY	. 7
30	9.0	TAP CONNECTION DEFINITION AND REQUIREMENTS	.9
31	10.0	LOOPED CONNECTION DEFINITION AND REQUIREMENTS	10
32	11.0	NETWORK CONNECTION DEFINITION AND REQUIREMENTS	10
33	12.0	VOLTAGE LEVELS	11
34	13.0	POWER FACTOR REQUIREMENTS	11
35	14.0	FREQUENCY RANGE	12
36	15.0	POWER QUALITY	12
37	16.0	SYNCHRONIZATION	14
38	17.0	GENERATION	14
39	18.0 IN	FORMATION REQUIRED	14
40	19.0 RE	EQUESTER'S FACILITY EQUIPMENT	16
41	20.0 SY	STEM PROTECTION	19
42	21.0	REVENUE METERING AND TELEMETRY REQUIREMENTS	20
43	22.0 CC	OMMUNICATIONS	22
44	23.0	TURNOVER INSPECTION REQUIREMENTS	23
45	23.1	MAINTENANCE REQUIREMENTS	23
46	24.0	COORDINATION WITH OTHER CODES, STANDARDS, AND AGENCIES 2	24
47	25.0		24
48	ATTAC	HMENT A: TYPICAL END-USER INTERCONNECTION	26

HOOSIERENERGY	Transmission and End-User	Effective Date: 1-12-24
RURAL ELECTRIC COOPERATIVE, INC.	Interconnection Requirements	Version: 8

49	ATTACHMENT B: TYPICAL TRANSMISSION INTERCONNECTION	27
50	ATTACHMENT C: VOLTAGE FLICKER CRITERIA AND HARMMONIC DISTORAT	ION
51	CRITERIA SUMMARY	28
52	ATTACHMENT D: ELECTRICAL CLEARANCES AND EQUIPMENT RATINGS	35
53	ATTACHMENT E PROTECTIVE LOOP INSTALLATION	36
54	26.0 APPROVALS	43

- 56 57 58

HOOSIERENERGY	Transmi
RURAL ELECTRIC COOPERATIVE, INC.	Intercon

59 **1.0 PURPOSE**

60 61

62

63

64

65

- Documents facility interconnection requirements for transmission Facilities and end user Facilities that may interconnect to Hoosier Energy's transmission system and control area.
- Updates facility interconnection requirements for generation owners that are already interconnected to Hoosier Energy's transmission system.
- Ensures safe interconnections to the Hoosier system to achieve necessary system performance throughout the planning horizon.
 - Verifies compliance with industry standards.
- 69

68

70 2.0 APPLICABILITY

This document applies to voltage levels of 69kV and above. Interconnections to Midcontinent ISO (MISO) Appendix G (non-transferred facilities) and

73 Appendix H (transferred facilities) are coordinated through the MISO and must

- adhere to North American Electric Reliability Corporation (NERC) reliability
- 75 standards.

76

3.0 HOOSIER CONTACT78

79 Transmission facilities and end-user facilities applying to interconnect with Hoosier 80 should contact the following:

0.1	-
01	• · -· · ·
82	Carl Field
83	Manager, System Planning
84	Office: 812-876-0536
85	
86	
87	
88	
89	
90	
91	
92	
93	
94	
05	
70	

4.0 PROCEDURES FOR COORDINATED STUDIES OF NEW OR EXISTING INTERCONNECTIONS WITH A QUALIFIED CHANGE AND THEIR IMPACTS ON AFFECTED SYSTEM(S) FAC-001-3 R3.1

99

When an interconnection request is submitted, and the applicable facility data and monetary deposits are routed to the appropriate recipients, MISO (when applicable) in conjunction with Hoosier Energy will carry out a series of system studies. This series of studies will continue as long as the request is active and will be terminated if the request is withdrawn. This series of studies commonly consists of the following but can vary depending on the type and complexity of each interconnection:

106

109

110

111

112

113

114

115116

117

- Feasibility Study
- 107 Feasibilit 108 Th
 - This is a high level evaluation of the proposed interconnection to identify potential problems that may be unacceptable to the stakeholders involved.
 - System Impact Study

This study is more detailed and is conducted to assess the effects the proposed connection has on transmission system adequacy and reliability. Transmission facility loadings, voltage profiles, power quality impacts, short circuit duties, and transient phenomena are examined over a range of expected system conditions. If the results of this study are acceptable to all stakeholders, a Facility Study will be performed.

Facility Study

118 This study will review and potentially repeat the System Impact Study and 119 develop the physical connection between the transmission system and a 120 proposed connected facility. The electrical configuration of the connection equipment including transformers, circuit breakers, other station 121 122 equipment, and required transmission line sections are determined. The 123 physical layout of equipment and right-of-way needs are also determined. 124 Multiple alternatives may be considered when developing facility 125 requirements. Cost estimates of required system upgrades for each 126 alternative are included.

128 The specific steps and requirements of the process for interconnecting new transmission 129 or modifying existing interconnections to Hoosier Energy's BES Transmission System are 130 set forth by MISO at the following site:

- 131
 132 <u>https://www.misoenergy.org/planning/transmission-planning/long-term-transmission-</u>
 133 <u>service-requests/</u>
- 134

- 135
- 136
- 137



5.0 PROCEDURES FOR NOTIFYING THOSE RESPONSIBLE FOR THE RELIABILITY OF AFFECTED SYSTEM(S) OF NEW OR EXISTING INTERCONNECTIONS WITH A QUALIFIED CHANGE FAC-001-4 R3.2

Hoosier Energy will follow the MISO Planning Coordinator procedures and the MTEP processes and upon notification of a facility connection request Hoosier Energy will notify the MISO Transmission Planning Coordinator and any potentially impacted neighboring entity of the facilities connection request. As facilities connection studies progress and additional information comes available, Hoosier will share that additional or updated information from the study result process with the neighboring reliability entities impacted by the requested facilities connection.

149

141

150 6.0 PROCEDURES FOR CONFIRMING WITH THOSE RESPONSIBLE

151 FOR THE RELIABILITY OF AFFECTED SYSTEM(S) OF NEW OR

152 TRANSMISSION FACILITIES WITH A QUALIFIED CHANGE ARE

153 WITHIN A BALANCING AUTHORITY AREA'S METERED BOUNDARIES

154 **FAC-001-4 R3.3**

As part of specifying metering equipment, settings, and requirements, Hoosier Energy shall determine that any new or transmission Facilities with a qualified change resulting from any Transmission connection to Hoosier Energy's transmission system are within the appropriate Balancing Authority Area's metered boundaries.

159

166

167 168

160 **7.0 DEFINITION OF QUALIFIED CHANGE**

FAC-001 requires Transmission Owners to have procedures for the coordination and notification of those having responsibility for reliability when existing facilities make a qualified change as defined by the Planning Coordinator. What constitutes a "qualified change" is defined by MISO's Transmission Planning Business Practices Manual BPM-020 as the following:

- transmission system topology change;
- protection configuration change that could negatively impact contingency performance, short circuit, or dynamic performance;
- change of the electrical characteristics of a circuit (i.e., change of impedance, current, transformers, lower thermal rating from replacement of components, change in underbuilds, line crossings, etc.) that could negatively impact contingency performance, short circuit, or dynamic performance.
- 174
- 175



176 8.0 SYSTEM IMPACT STUDY

177 In order to assess the impact of a proposed facility connection on system reliability. system impact studies need to be conducted. These system impact studies, as a 178 179 minimum, examine the transmission line and transformer loading, voltage profiles and 180 schedules, generation capacity (MW) provided a point of connection; minimum reactive 181 (MVAR) requirements and power quality impacts of the proposed facility for a range of 182 expected seasonal loading and power transfer conditions. The effect of the proposed 183 facility on short circuit duties is examined for all proposed transmission connections. A 184 multi-step approach to the proposed facility may be considered where the impact of 185 each step is assessed separately. Alternative plans of service may be considered.

186 8.1 POWER FLOW ANALYSES

187 Power flow analyses (steady-state and transient) are conducted to examine the impact 188 of the proposed facility on transmission lines and transformers, and voltage profiles. 189 These analyses may typically determine the maximum load demand in the case of End-190 User facilities or through flow in the case of a Transmission Interconnection that can be 191 accommodated with minimal or no upgrades to the transmission system. Contingencies 192 consisting of single or multiple outages of lines and/or transformers are considered in 193 these analyses. Where the analyses indicate that transmission upgrades are necessary. 194 alternative reinforcement plans may be devised and evaluated for their capability to 195 accommodate the proposed facility. These analyses may also indicate a need to 196 perform dynamic studies.

197

198 8.2 SHORT CIRCUIT ANALYSES

Short circuit analyses are conducted to examine the impact of the proposed facility on
 equipment duties. These analyses are primarily concerned with **Transmission Interconnection** facilities. Increased fault duties may require upgrading existing circuit
 breakers and other facilities.

The criteria Hoosier Energy uses to determine what constitutes acceptable performance in the above system impact studies is readily available from Hoosier Energy's FERC Form 715 filing.

206 8.3 ADDITIONAL ANALYSES

Other analyses may be required as part of system impact studies based on power flow
 analysis and depending on the nature of the proposed connected facility and its location
 within the transmission network:

• Power quality analyses are undertaken for all **End-User** load that could potentially cause harmonic current or voltage, voltage flicker, and/or telephone interference. • The possibility of adverse subsynchronous torsional interaction is investigated wherever the end-user's equipment such as arc-furnaces and/or cycloconverters is to be located in close electrical proximity to existing generation.

Criteria for harmonic interference, voltage flicker, and telephone interference are included in the document appendices. As for adverse torsional interaction, the criteria are wholly dependent on the specifics of any nearby generation.

The scope of all the above system impact studies will be determined by Hoosier Energy based on the type, location, and power level of the proposed facility. Normally, MISO will perform the system impact studies. The cost of these studies will be chargeable to the **Transmission Interconnection** or **End-User** in accordance with the applicable tariff. A report documenting the assumptions, results, and conclusions of the system impact studies is made available to the **Transmission Interconnection** or **End-User**.

Hoosier Energy and MISO must be notified of new facilities, upgrades, or additions such as an increase in load or generating capability of existing facilities connected to the transmission system within the Hoosier Energy Control Area. System impact studies are to be conducted to determine the need for any upgrades of transmission equipment or transmission reinforcements to the Hoosier Energy system to accommodate the changes in the connected facility.

8.4 DETAILED PLAN OF SERVICE

231

234 A detailed plan of service will be developed by Hoosier Energy to provide for the 235 physical connection between the transmission system and a proposed connected 236 facility. The electrical configuration of the connection equipment including transformers, 237 switchgear and other station equipment, and required transmission line sections are 238 determined. Attachment A illustrates some of the more typical configurations for plans 239 of service, but other possibilities exist depending on the particular situation. The 240 physical layout of equipment and right-of-way needs are determined in the plan of 241 service as well. Typically, more than one alternative is considered in developing a plan 242 of service depending upon the accessibility of the local area transmission facilities and 243 the needs of the proposed connected facility. A multi-step approach may be considered 244 in the plan of service to accommodate a multi-step increase in load for the connected 245 facility.

246 8.5 RESPONSIBILITIES

Transmission Interconnection and/or **End-Users** are generally responsible for the costs associated with connecting to the Hoosier Energy Transmission System in accordance with the applicable tariff. The information contained herein is subject to change and may be revised at any time.



9.0 TAP CONNECTION DEFINITION AND REQUIREMENTS

Any connection to the Hoosier Energy transmission system that results in only the **End-User** load to pass through the connecting facilities under any condition is considered a tap connection.

255 Figure 1 in Attachment A illustrates typical End-User Interconnection configurations and 256 some of the basic connection requirements. As indicated, line switches are typically the 257 minimum requirements at the tap location point. The in-line air break switches allow for sectionalizing the line without supply interruption to the End-User and the tap line air 258 259 break switch can disconnect the End-User without outaging the supply line. Motor operated mechanisms (with or without supervisory control) may be required on mainline 260 261 air break switches to minimize the time required for restoration following a failure on the 262 Hoosier Energy/End-User supply line. Hoosier Energy reserves the right to require the 263 above listed equipment in the interconnection configuration. Hoosier Energy also 264 reserves the right to require additional protection devices and configurations depending 265 on the location and situation.

Figure 2 in Attachment A represents a Transmission Interconnection configuration for the Hoosier Energy transmission system and some of the basic connection requirements. Both a ring bus and a breaker-and-a-half scheme are acceptable. Hoosier Energy reserves the right to require the above listed equipment in the interconnection configuration. All connections above 230 kV regardless of End-User or Transmission Interconnection will be required to be treated as a Transmission Interconnection.

273

In general, connecting to a Hoosier Energy substation bus would use transformer switching arrangements similar to that required for tapped line supply configurations. The substation bus connections will be reviewed on a case-by-case basis. In all cases connections to a Hoosier Energy substation bus will require review and additional expense for the End-User or Transmission Interconnection requestor. For connections that are up to 230 kV, the requester should be prepared to include:

280 281

282

283

284

285

- Motor operated full-load break switches required on the main line.
- Manually operated air-break switch required on the tap line, unless the tap line is longer than 1 span. A line longer than 1 span may require a motor operated tap line switch.
- Substation high-side disconnect switch and protective device.
- For loads that do not exceed 10 MVA, fused protection is the typical requirement.
- For loads that are more than 10 MVA, or any voltage above 100 kV, a circuit 288 breaker or circuit switcher is the typical requirement.
- An inline metering station with circuit breaker may be required at the option of Hoosier Energy at the tap point of the Hoosier Energy main line.

HOOSIERENERGY	Transmission and End-User	Effective Date: 1-12-24
RURAL ELECTRIC COOPERATIVE, INC.	Interconnection Requirements	Version: 8

For **End-User** tap supply configurations, either a delta or ungrounded-wye high side transformer winding configuration is preferred. The installation of a grounded-wye high side transformer could require additional protection facilities and costs to be borne by the **End-User**. Transmission interconnections shall interface the Hoosier Energy system with a grounded-wye winding configuration.

10.0 LOOPED CONNECTION DEFINITION AND REQUIREMENTS

Any connection to the Hoosier Energy Transmission System that provides two line extensions to supply the **End-User** is considered a looped connection. In general, the two line extensions are installed to facilitate **End-Users** obtaining looped service, not to enable Hoosier Energy to provide adequate electrical service to any location other than the **End-User**.

302 Since some looped connections have the potential to significantly affect the reliability 303 and loadability of the Hoosier Energy Transmission System, specific design and 304 operational requirements are imposed which may not be required for a tapped 305 connection. In addition to the requirements outlined in Section 20.0, the following 306 conditions apply:

- 307
- For voltages greater than 100 kV, but less than 230 kV, the preferred connection is through a ring-bus and optionally a breaker-and-a-half scheme. Other configurations may be allowed at the discretion of Hoosier Energy.

11.0 NETWORK CONNECTION DEFINITION AND REQUIREMENTS

312 Any connection to the Hoosier Energy Transmission System that allows bi-directional 313 energy and/or fault current flow between otherwise independent transmission systems 314 is considered a network connection. This is considered a special circumstance, which 315 requires a detailed system impact study to determine the acceptability of the proposed transmission interconnection and the specific interconnection requirements. 316 Transmission interconnection requests on the Hoosier Energy Transmission System 317 318 will be considered on a case- by-case basis. The Transmission Interconnection Requester¹ will be responsible for reimbursement of the cost for these studies 319 320 (generally done by MISO). In addition, the cost of facilities to establish and reliably integrate the new network connection will be at the expense of the Transmission 321 Interconnection Requester to the extent allowed by the appropriate MISO Tariff 322 323 documents.

¹ **Transmission Interconnection Requester** -refers to the entity requesting a network transmission interconnection to the Hoosier Energy transmission system.



324 **12.0 VOLTAGE LEVELS**

The **Transmission Requester's**² facility will be supplied from Hoosier Energy's Transmission System, which generally under system normal conditions and single transmission element outage conditions can range between 90% and 105% of nominal. If the **Requester's** supply voltage requirements are more restrictive than the 92% to 105% range, Hoosier Energy recommends that the **Requester** consider the addition of voltage regulation equipment in their facility. Nominal transmission system voltages presently on the Hoosier Energy system are: 345 kV, 161 kV, 138 kV and 69 kV.

Under certain emergency conditions, the Hoosier Energy Transmission System may operate for a period of time outside of the 90% to 105% range. The **Requester** is responsible for providing any voltage sensing equipment required to protect their equipment during abnormal voltage operation.

13.0 POWER FACTOR REQUIREMENTS

The NERC Planning Standards state that distribution entities and customers connected directly to the transmission systems should plan and design their systems to operate at close to unity power factor to minimize the reactive power burden on the transmission systems. The Hoosier Energy interpretation of "close to unity power factor" is that the power factor of the connected load should be within the range of approximately 0.98 lagging to 0.98 leading.

343 Unless otherwise restricted by Retail Tariffs, the maximum hourly reactive power 344 (kVAR) demand, both leading and lagging, will be identified each month at the delivery 345 point(s). An End-User will incur no charges for power factor if the maximum leading and lagging kVAR demands do not exceed 20% of the real power (kW) demand in the 346 347 same hour(s). If the maximum hourly leading and/or lagging kVAR demands exceed 348 20% of the corresponding kW demand, charges will be assessed. The charge will be 349 one rate per kVAR for all leading and/or lagging kVAR demand in excess of 20% of the 350 corresponding kW demand. When the leading and/or lagging kVAR demand exceeds 351 50% of the corresponding kW demand, the charge will be a higher rate per kVAR, for 352 all kVAR in excess of 20% of the kW demand. The cost of reactive demands for Hoosier 353 Energy full requirements customers will be based on the applicable state or FERC filed 354 tariff.

Capacitors generally provide an effective means of controlling the power factor of a **Requester's** facility. However, there are several factors that should be addressed in

² Transmission Requester - can refer to either a Transmission Interconnection Requester or a Transmission End-User Requester and hereinafter is referred to as a Requester.

HOOSIERENERGY	Transmission and End-User	Effective Date: 1-12-24
RURAL ELECTRIC COOPERATIVE, INC.	Interconnection Requirements	Version: 8

applying capacitors. These factors can include, but are not limited to, transient voltages
 due to capacitor switching and voltage amplification due to resonance conditions. The
 services of a Hoosier Energy approved consultant should be obtained to review the
 specific application and provide recommendations in regard to control of these
 phenomena.

36214.0FREQUENCY RANGE

The Hoosier Energy transmission system typically operates at a nominal 60 Hz with a variation of +0.05 Hz to -0.05 Hz. Under certain emergency conditions, the transmission system may operate for a period of time outside of this range. The **Requester** is responsible for providing any frequency sensing equipment required to protect their facility during abnormal frequency operation.

368 **15.0 POWER QUALITY**

369 15.1 HARMONICS AND FLICKER

370 Certain electrical equipment located at the End-User's facility (arc furnaces, cycloconverters, etc.) will generate voltage flicker³ and harmonic distortion which can 371 negatively impact other End-Users. Should this be the case, the End User shall take 372 responsibility, initially or in the future, for limiting interfering levels of harmonic voltage 373 and current distortion and/or voltage flicker. Limits for harmonic distortion (including 374 375 inductive telephone influence factors) are as published in the latest issues of ANSI/IEEE 376 519, "Recommended Practices and Requirements for Harmonic Control in Electrical 377 Power Systems."

378

379 Specific Hoosier Energy harmonics and flicker criteria are given in Attachment C. 380 Hoosier Energy criteria requires that flicker occurring at the point of compliance shall 381 remain below the Border Line of Visibility curve on the IEEE/GE curve for fluctuations less than 1 per second or greater than 10 per second. However, in the range of 1 to 10 382 383 fluctuations per second, voltage flicker shall remain below 0.4% (see Attachment C, Exhibit 1). Hoosier Energy may, initially or in the future, require the installation of a 384 385 monitoring system to permit ongoing assessment of compliance with these criteria. The monitoring system, if required, will be installed at the End-User's expense. 386

387 Situations where high harmonic voltages and/or currents originate from the transmission388 system are to be addressed in the Connection Agreement.

15.2 SENSITIVE ELECTRICAL EQUIPMENT

³ Flicker is an objectionable, low frequency, voltage fluctuation which can be observed through changes in intensity or color of illumination

HOOSIERENERGY	Transmission and End-User	Effective Date: 1-12-24
RURAL ELECTRIC COOPERATIVE, INC.	Interconnection Requirements	Version: 8

390 Certain electrical equipment in the **Requester's** facility may be sensitive to normally

391 occurring electric interference from nearby connected loads in the **Reguester's** facility, 392 from other End-Users connected to the power system, from natural causes, and system 393 switching, etc. If sensitive electrical equipment is to be supplied directly from the electric 394 power system, it is recommended that the equipment grounding requirements and 395 power supply requirements be examined by the Requester or the Requester's 396 consultant prior to installation. Attention should be given to equipment tolerance to 397 various forms of electric interference, including voltage sags and surges, momentary 398 outages, transients, current and voltage harmonic distortion, or other electrical and 399 electromechanical noise. When electrical disturbances to sensitive electrical equipment 400 such as computers, electronics, controls, and communication equipment cannot be 401 tolerated, the End-User shall install additional equipment as may be necessary to 402 prevent equipment malfunctions and protect against equipment failure. The End-User 403 should consult the supplier of such sensitive electrical equipment regarding the power 404 supply requirements or the remedial measures to be taken to alleviate potential mis-405 operation or failure of the equipment. The **End-User** may need to hire a power quality consultant to also perform a site survey of the electric power supply environment and 406 407 furnish recommendations to provide the acceptable levels of reliability and quality of 408 service.

409 15.3 TRANSFORMER PROTECTIVE DEVICES

Hoosier Energy requires End-Users to install circuit switchers and/or circuit breaker.
 Hoosier Energy will allow fuses as an exception for voltages <69kV and <10 MVA.

412 **15.4 UNBALANCED ELECTRIC CONDITIONS**

413 **15.4.1 VOLTAGE BALANCE**

Voltage unbalance attributable to the End-User facilities shall not exceed 1.0%
measured at the point-of-service. Voltage unbalance is defined as the maximum phase
deviation from average as specified in ANSI C84.1-2011, "American National Standard
for Electric Power Systems and Equipment Voltage Ratings, 60 Hertz."

418 15.4.2 CURRENT BALANCE

419 Phase current unbalance attributable to the **End-User** facility shall not exceed that 420 which would exist with balanced equipment in service, measured at the point-of-421 common coupling.

422 Situations where high unbalance in voltage and/or current originate from the 423 transmission system are to be addressed in the Connection Agreement.

424 15.5 SUBSYNCHRONOUS TORSIONAL INTERACTION

HOOSIERENERGY	Transmission and End-User	Effective Date: 1-12-24
RURAL ELECTRIC COOPERATIVE, INC.	Interconnection Requirements	Version: 8

425 Certain End-User equipment, in particular electric arc furnaces and cycloconverters, 426 may cause adverse interactions and possible damage to existing turbine-generators 427 located in close electrical proximity. These situations will be analyzed by Hoosier 428 Energy, or Hoosier Energy's consultant, and appropriate corrective or preventive 429 measures identified. Corrective and preventive measures may consist of torsional 430 current monitoring, special protective relaying on the turbine-generator shaft(s), or 431 constrained operation of the End-User equipment under certain system configurations. 432 Costs of studies and the design and installation of protective and/or monitoring equipment shall be the responsibility of the Requester. 433

434

435 **16.0 SYNCHRONIZATION**

436

The Transmission Facility Owner and End User shall assume all responsibility for
 properly synchronizing their transmission for operation with the Hoosier Energy
 Transmission System, and for remaining synchronized with Hoosier Energy in
 accordance with industry accepted practice.

- 441 **17.0 GENERATION**
- 442

Generation connected to and operated in synchronism with the Hoosier Energy
 transmission system in conjunction with End-User load is subject to additional
 requirements beyond those specified in this document. Information concerning these
 requirements is contained in "Requirements for Connection of Generation to the Hoosier
 Energy Transmission System." The Generation Facility Owner should contact the
 local Hoosier Energy Industrial/Commercial Service Representative for this document.

449

450 18.0 INFORMATION REQUIRED

451

457

458

459

As soon as available, the **Requester** shall provide two copies of the following
information for review and comment by both the Technical Assets and the Design
Services groups at Hoosier Energy, as well as to MISO.

- 455 a. **Requester's** Information
- company name
 - mailing address
 - contact representative
 - phone number
- 460 b. Project Design/Engineering Information
- company name
- mailing address
- contact representative

HOOSIERENERGY RURAL ELECTRIC COOPERATIVE, INC. Transmission and End-User Interconnection Requirements

464		phone number
465 466	C.	Requested in-service date for the transmission connection, and for temporary service to test facilities prior to formal in-service.
467 468	d.	Plot plan or description showing exact location and orientation of Requester's proposed facilities and point of electric service delivery.
469 470	e.	One-line, schematic diagrams, plan and elevation drawings of the proposed facilities showing dimensions, clearances and grounding layout.
471 472	f.	Information on characteristics of load, including initial load build-up, 5 and 10 year load projections, and power factor of such loads.
473 474 475	g.	Information concerning the Requester's power factor correction equipment. This should include size and amount of fixed or switched capacitors, or other power factor correction equipment and methods used for operation.
476 477 478 479	At least th the follow Delivery E manner n	nree months before starting electrical construction of the Requester's facility, ing additional information must be sent to Hoosier Energy's Manager of Power Engineering or their designee(s). Failure to provide this information in a timely may delay the facility in-service date.
480	h.	Data on equipment to be installed.
481 482 483 484 485 486 486 487	i.	 High side interrupting and sectionalizing devices – Manufacturer Type Voltage rating Current ratings. ii. High side relaying equipment with complete manufacturer's data.
488 489 490 491 492 493		iii. Power transformers -Complete nameplate and test report data, including manufacturer, serial number, high and low side voltage taps, kVA ratings, high and low side connections, low side grounding (if used), load loss watts and positive and zero- sequence impedances between the high-low, high-tertiary, and low-tertiary transformer windings (as applicable) at each tap.
494 495		 iv. Data on Requester's low voltage protection equipment, including fuses, breakers, relays, and relay settings.
496 497 498	The inform studies in energizat	mation in subsections h and i is required to perform coordination selectivity a timely manner. Any disagreement in this regard must be resolved prior to ion.

- Depending upon the nature of the End-User equipment to be installed, the following 499
- 500 data may be required to complete the portion of the system impact studies addressing

HOOSIERENERGY	Transmission and End-User	Effective Date: 1-12-24
RURAL ELECTRIC COOPERATIVE, INC.	Interconnection Requirements	Version: 8

- 502j.Data on the harmonic and sub-harmonic current/voltage spectra of the end-
user equipment to be installed under three phase balanced and unbalanced
conditions.
- 505k. Maximum magnitudes (MW and MVAR) of sudden load swings at the point506of connection and the number of such fluctuations per second, minute or507hour.
- 508 I. Data on SVC equipment and harmonic filters if applicable.
- 509 m. Maximum expected MW and MVAR demand at the point of connection.

19.0 REQUESTER'S FACILITY EQUIPMENT

51119.1 SIZE AND TAKE-OFF TENSION OF LINE CONDUCTORS AND512OVERHEAD GROUND WIRES

513 The **Requester's** structure shall be designed for on a case-by-case basis in accordance 514 with Rule 250 of the National Electric Safety Code (NESC). The exact take-off tensions 515 will be determined after the facility plans are finalized.

The line terminal connectors furnished by the **Requester** should be (copper or aluminum) wire-and-pad connector to bolt to and be materially compatible with the air switch terminal pad. The overhead ground wire shall be grounded using aluminum compression wire and a pad type connector furnished by the **Requester**.

520 If the incoming high voltage lines will cross road ways or railroad tracks, such as a siding 521 or main line, to reach the **Requester's** facility, it may be necessary to increase the 522 above tensions or provide additional height on the structure to meet appropriate 523 crossing requirements.

524 The point of attachment of the line entrance conductors shall be of sufficient height to 525 provide the basic vertical clearance requirements for lines crossing over public streets, 526 alleys, or roads in urban or rural districts, as outlined in the NESC.

19.2 SHORT CIRCUIT DATA & INTERRUPTING DEVICE RATINGS

528 The following estimated short circuit levels will be provided by Hoosier Energy at the 529 point of common coupling.

530 Estimated Initial Short Circuit Levels (Year)

531	3 Phase Fault:	MVA	ANSI X/R Ratio
532	Phase-to-Ground Fault*:	MVA	ANSI X/R Ratio

533 Estimated Future Short Circuit Levels (Year)

534	3 Phase Fault:	MVA	ANSI X/R Ratio
535	Phase-to-Ground Fault*:	MVA	ANSI X/R Ratio

RURAL ELECTRIC COOPERATIVE, INC.	Transmission and End-User	Effective Date: 1-12-24
	Interconnection Requirements	Version: 8

*Note: Phase-to-ground fault values are calculated assuming the **Requester's** transformers have either a wye-ungrounded or delta connected high side. For wyegrounded transformers, the transformer contribution to the total fault current will have to be considered and the fault values recalculated.

541 **Transmission Interconnection** and **End-Users** equipment should have adequate 542 interrupting and momentary ratings for the future short circuit conditions listed above.

543 While Hoosier Energy will endeavor, where possible, to anticipate system changes which may affect these values, it does not assume responsibility or liability with respect 544 545 to such protective devices, nor guarantee their continuing adequacy against increased interrupting capacity requirements resulting from system changes. Transmission 546 Interconnection and End-Users who use this information should periodically review 547 existing and future fault conditions and equipment ratings for adequacy. Any equipment 548 549 replacements or upgrades to maintain adequacy of the Transmission Interconnection or End-Users' facilities will be at the Transmission Interconnection or End-Users' 550 551 expense.

All gas insulated protective devices within the **Requester's** facility having a direct connection to an Hoosier Energy transmission line shall be equipped with a low gas pressure alarming/tripping/lockout scheme as appropriate for the particular device.

19.3 OTHER DESIGN CRITERIA

19.3.1 EQUIPMENT BASIC INSULATION LEVELS

557 The minimum required Basic Insulation Levels (BIL) for stations are listed in Attachment 558 D. Facilities in areas with significant airborne pollution may require a higher insulation 559 level. The Requester will coordinate insulation levels to meet Hoosier Energy 560 requirements in Attachment D.

19.3.2 TRANSFORMER SURGE PROTECTION (LIGHTNINGARRESTERS)

Lightning arresters protecting transformers are generally porcelain design and mounted on the transformer. However, since lightning arresters can adequately protect equipment some distance from the arresters, the overall number of lightning arresters required in each design can be reduced. Lightning arrester allowable separation distance from the equipment being protected is based on Table 4 of IEEE Std. C62.22.

568 The **Requester** should consult the manufacturer's catalog for details concerning 569 arrester protective characteristics, ratings, and application.

19.3.3 CURRENT CARRYING EQUIPMENT RATINGS

HOOSIERENERGY	Transmission and End-User	Effective Date: 1-12-24
RURAL ELECTRIC COOPERATIVE, INC.	Interconnection Requirements	Version: 8

571 For tap and looped connections, the **Requester's** high voltage bus and associated 572 equipment, such as switches, connectors, and other conductors shall have minimum 573 continuous current and momentary asymmetrical current ratings which: (1) do not limit 574 the Hoosier Energy transmission system network capability and (2) have adequate 575 capability for the initial and future system conditions identified by Hoosier Energy.

19.3.4 ELECTRICAL CLEARANCES (OUTDOOR)

577 Electrical facility design clearances are listed in the table in Attachment D. These design 578 clearances should be used for electrical facilities up to and including any interrupting 579 device connected directly to a Hoosier Energy transmission line and for all facilities that 580 are part of the Hoosier Energy transmission system.

581 The minimum vertical clearance of the conductors above ground and the vertical and 582 horizontal clearance of conductors passing by but not attached to a building or wall shall 583 be in accordance with the NESC or applicable state and local codes.

58419.3.5 INSULATORS FOR STATION

585 The required station post insulator types are listed in the table in Attachment D. Facilities 586 in areas with significant airborne pollution may require a higher insulation level. Higher 587 strength insulators are available and should be used if needed to meet bus momentary 588 short circuit values.

19.3.6 AIR BREAK SWITCH (ES) AND DISCONNECT SWITCH (ES)

A group operated switch shall be installed on each transmission line supply entrance to the **Requester's** facility and accessible to Hoosier Energy personnel at all times. The switch shall be mechanically lockable in the open position with an Hoosier Energy padlock in order to provide for a visible electric isolation of the **Requester's** facility and shall be identified with an Hoosier Energy designated equipment number.

595 All air-break switches shall be three phase, single throw, group operated. Disconnect switches shall be three pole, single throw devices. Characteristics for all air break 596 597 switches and disconnect switches including voltage and BIL ratings, clearances and pole spacing shall meet the requirements shown in the table in Attachment D. There 598 599 shall be no braids in the current carrying parts of the switch. Group operated switches shall be complete with a horizontal, rotating-type operating handle. A grounding device 600 601 is to be furnished for the operating shaft and shall consist of a tin coated, flexible copper 602 braid, located as close as possible to the operating handle. The braid shall have a crosssectional area equivalent to 4/0 copper cable, or greater. The braid shall be secured to 603 604 the shaft by means of a galvanized steel V-bolt clamp and associated cradle-type galvanized steel hardware. The opposite end of the braid shall have two (2) 9/16 inch 605

- 606 holes at 1-3/4 inch spacing. Both ends of the braid shall be stiffened and protected by 607 a ferrule or additional tinning.
- As a minimum, a protective grounding loop shall be provided around all group operated
- 609 switches as illustrated in Attachment E. This table applies to areas where native soil
- resistivity does not exceed 500 Ohm-meters. When the above condition is exceeded a
- 611 detailed engineering assessment study must be undertaken by Hoosier Energy.
- All switches shall be manufactured and tested in accordance with the latest revision of ANSI C37.30, ANSI C37.32, and ANSI C37.34.

614 **19.3.7 FACILITY FENCE SAFETY CLEARANCES**

The fence safety clearances in the **Requester's** facility shall comply with Section 11 of

616 ANSI C2-2012, "National Electrical Safety Code."

617 19.3.8 GROUND SYSTEM RESISTANCE

- The grounding system should be designed in accordance with IEEE Standard 80 -latest revision, "IEEE Guide for Safety in AC Substation Grounding." In evaluating the step and touch potential the target body weight value should be set to 50 kg.
- Ground fault levels from Hoosier Energy sources are listed in Section 11.2, Short Circuit Data & Interrupting Device Ratings. **Requester** equipment ground sources can contribute significant fault current independent of the ground fault values in Section 11.2. These **Requester** ground sources should be considered in the design of the grounding system.
- 626

If the facility structure is to be wood-pole type construction, the transmission line
 overhead ground wire, all switch bases, fuse bases, and other noncurrent-carrying
 metal parts shall be grounded to the station grid.

630

631 20.0 SYSTEM PROTECTION

632 20.1 TRANSMISSION PROTECTION

The **Requester** is responsible for functional specifications and relay settings for all 633 634 protective relays at the **Requester's** facility that have a potential impact on the reliability 635 of the Hoosier Energy transmission system. Hoosier Energy reserves the right to specify the type and manufacturer for these protective relays to ensure compatibility 636 with existing relays. The specific recommendations and requirements for protection will 637 638 be made by Hoosier Energy based on the individual substation location, voltage, 639 configuration, utility grade relays, including fault recording, redundant protection, battery 640 requirements, relay failure alarming, etc.



641 20.2 REQUESTER PROTECTION

642 It is the **Requester's** responsibility to assure protection, coordination, and equipment 643 adequacy within their facility for conditions including but not limited to:

- 644 1. single phasing of supply,
- 645 2. system faults,
- 646 3. equipment failures,
- 647 4. deviations from nominal voltage or frequency,
- 5. lightning and switching surges,
- 649 6. harmonic voltages,
- 650 7. negative sequence voltages,
- 651 8. separation from Hoosier Energy supply,
- 652 9. synchronizing generation.

653 20.3 AUTOMATIC UNDER-FREQUENCY LOAD SHEDDING

Hoosier Energy may require automatic under-frequency load shedding relaying on
 connected loads to comply with NERC EOP-003 "Load Shedding Plans" and PRC-006
 or other system stability considerations.

657 20.4 TAP CONNECTED FACILITIES

658 Remote relay access is not normally required at tap connected facilities.

20.5 LOOP OR NETWORK CONNECTED FACILITIES

All digital relays which have the capability of recording system disturbance information
 and are used for protection of Hoosier Energy transmission facilities shall be provided
 with the equipment necessary to allow Hoosier Energy to remotely retrieve this data via
 Requester supplied access.

664 21.0 REVENUE METERING AND TELEMETRY REQUIREMENTS

665 21.1 REVENUE METERING

666 Hoosier Energy approved revenue class metering equipment shall be installed at the 667 delivery point to meter the aggregated load of the connected facility consisting of 668 instantaneous bi-directional real and reactive power and integrated hourly real and 669 reactive energy metering.

The metering equipment will include potential and current transformers, meters and test switches. The accuracy of the instrument transformers and meters will be 0.3 percent or better. The secondary wiring and burdens of the instrument transformers will be

RURAL ELECTRIC COOPERATIVE, INC.	Transmission and End-User	Effective Date: 1-12-24
	Interconnection Requirements	Version: 8

673 configured so that they do not degrade the total accuracy by more than 0.3%. The 674 metering equipment will be tested periodically as defined in the service agreement and 675 the test results will be available to all involved parties. The meters, test switches and 676 wiring termination equipment will be sealed, and the seal may be broken only when the 677 meters are to be tested, adjusted, or repaired. Representatives from both parties will be 678 notified when seals are broken.

At least (N-1) metering elements will be used to measure all real and reactive power crossing the metering point, where N is the number of wires in service including the ground wire. Bi-directional energy flows including watt-hour and var-hour will be separately measured on an hourly basis.

Depending on the tariffs to be applied, appropriate demand quantities will be metered
 in terms of kilowatts, kilovars or kilovolt-amperes. If required, voltage measurements
 will be provided.

The instrument transformers used for revenue metering shall be installed on the high voltage side of the **Requester's** step-down transformer. Under special circumstances and with written approval granted by Hoosier Energy, revenue metering may be performed on the low voltage side of the step-down transformer. Written approval shall only be given if the **Requester** can demonstrate that accurate transformer loss compensation will be programmed into the revenue metering when instrument transformers are installed on the low voltage side of the step-down transformer.

693 **21.2 TELEMETRY**

694 Suitable telemetry equipment will be installed at the metering point to provide real-time 695 telemetry data to Hoosier Energy and to all other participating parties.

696

697 Telemetry equipment will include transducers, remote terminal units, modems, 698 telecommunication lines, radio equipment and any other equipment of the same or 699 better function. The remote terminal unit must have multiple communication ports to 700 allow simultaneous communications with all participating parties. The device will 701 accommodate data communication requirements specified by each participating parties 702 control center, including communication protocol, rate and mode (either synchronous or 703 asynchronous). All metered values provided to the telemetry equipment will originate 704 from common metering equipment. All transducers used for telemetry will have at least 705 0.3% accuracy. As part of real-time data to be provided, Hoosier Energy has the right 706 to require the status and remote control of switching devices at the Receipt and/or 707 **Delivery Points.**

A continuous, accumulating record of megawatt-hours and megavar-hours will be provided by means of the registers in the meter. Freezing accumulation data for transmission will be taken every clock hour. The freezing signals synchronized to within 2 seconds of Eastern Standard Time or time defined by MISO must be provided by only one of the agreed-upon participating parties. If the freeze signal is not received within a predefined time window, the remote terminal unit, or equivalent device, will be capableof freezing data with its own internal clock.

715 The metering, and telemetry equipment will be powered from a reliable power source, 716 such as a station control battery, to allow the equipment to be continuously operational 717 under any abnormal power supply situations. Proper surge protection will be provided 718 for each communication link to protect communication hardware from ground-potential-719 rise due to any fault conditions. A separate communication media shall be provided to 720 allow Hoosier Energy to remotely retrieve billing guantities from the meters. When real-721 time telemetry is required, a back-up data link must be provided in case of the outage 722 of the primary telemetry line. The back-up link can be a data communication link 723 between involved control centers; the party requesting service is responsible for 724 furnishing the back-up link.

725 **22.0 COMMUNICATIONS**

726 22.1 VOICE COMMUNICATIONS

A. Normal - At Hoosier Energy's request, the **Requester** shall provide a dedicated voice communication circuit to the Hoosier Energy System Control Center (SCC). Such a dedicated voice communication circuit would originate from the **Requester's** office staffed 24 hours a day and would be typically required for connected transmission facilities that significantly affect the Hoosier Energy transmission network capacity and operations.

All other normal voice communication concerning facility operations shall be conducted
 through the public telephone network to the SCC phone number(s) issued by Hoosier
 Energy.

B. Emergency - Voice communications in the event of a transmission facility emergency shall use the dedicated voice circuits, if available, or public telephone network and phone number(s) designated for emergency use.

739 It is the **Requester's** responsibility to take prudent steps when an area or system wide 740 capacity emergency is declared. Load reductions shall be implemented by reducing 741 non-essential loads. This type of reduction is usually conveyed through the local media. 742 Interruptible customer load reductions may already be in effect depending on the nature 743 of the emergency. The End-User's Hoosier Energy representative is responsible for 744 providing the respective Hoosier Energy Transmission Dispatch Center (TDC) a 745 "customer contact list." This listing contains the End-User's Hoosier Energy 746 representative and backup person as well as their business, home and pager numbers.

These **End-Users** shall be provided an unlisted phone number to be used for emergency or routine operations. Operational emergencies (equipment) warrant a direct call either way. The TDC will advise the Hoosier Energy representative of problems that they should handle directly with the **End-Users**.

RURAL ELECTRIC COOPERATIVE, INC.	Transmission and End-User	Effective Date: 1-12-24
	Interconnection Requirements	Version: 8

752 22.2 INTERRUPTIBLE CONTRACTS

753 Owners of transmission facilities that have an Hoosier Energy interruptible contract shall 754 install communication facilities with the Hoosier Energy TDC specified in the contract.

755 **22.3 EMERGENCY OPERATING CONDITIONS**

End-User's facilities may be subject to Hoosier Energy 's Emergency Operating Plan
 (EOP) and other applicable plans which can require interruption of load to deal with
 generation deficiencies and/or transmission system emergencies.

It is noted that interrupting of load will only be done in extreme conditions that would result in a more serious degradation of system performance than if the load were not shed.

762 System emergencies are communicated through the local media. Interruptible 763 customers are also notified electronically in the event of an "Emergency Interruption."

764 23.0 TURNOVER INSPECTION REQUIREMENTS

765 Before a **Requester** owned facility can be energized, it must pass a final turnover inspection by Hoosier Energy personnel. Hoosier Energy will inspect all substation 766 equipment from the point of interconnection to the first protective fault interrupting 767 768 device and the ground system. This may include circuit breakers, circuit switchers, 769 power fuses, instrument transformers, switches, surge arresters, bushings, and relays 770 and associated equipment (including battery and battery chargers). The inspection will 771 consist of a visual inspection of all major equipment as well as review of required test 772 results.

The ground system must be checked by using the resistance measurement procedures
 in accordance with IEEE Standard 81 "Recommended Guide for Measuring Ground
 Resistance and Potential Gradients in the Earth."

The inspection will be performed by Hoosier Energy personnel who will document the inspection. An example of the form, showing the types of information required is shown in Attachment F.

779 23.1 MAINTENANCE REQUIREMENTS

All **Requester** owned equipment up to and including the first protective fault interrupting device is to be maintained to Hoosier Energy standards. This includes circuit breakers, circuit switchers, power fuses, instrument transformers, switches, surge arresters, bushings, relays, and associated equipment (including battery and battery charger). Maintenance procedures are detailed in the Hoosier Energy "Maintenance Plan".

RURAL ELECTRIC COOPERATIVE, INC.	Transmission and End-User	Effective Date: 1-12-24
	Interconnection Requirements	Version: 8

785 The **Requester** shall have an organization approved by Hoosier Energy test and maintain all devices and control schemes provided by the Requester for the protection 786 787 of the Hoosier Energy system. Included in the testing and maintenance will be any initial 788 set up, calibration, and check out of the required protective devices, periodic routine 789 testing and maintenance, and any testing and maintenance caused by a Requester or 790 Hoosier Energy change to the protective devices. All testing and maintenance shall be 791 coordinated with Hoosier Energy and as necessary with MISO via the CROW system 792 for coordinating generation outages.

If the **Requester's** testing and maintenance program is not performed in accordance with Hoosier Energy's "Maintenance Plan". Hoosier Energy reserves the right to inspect, test, or maintain the protective devices required for the protection of the Hoosier Energy System.

All costs associated with the testing and maintenance of devices provided by the **Requester** for the protection of the Hoosier Energy system, including costs incurred by Hoosier Energy in performing any necessary tests or inspections, shall be the responsibility of the **Requester**.

Hoosier Energy reserves the right to approve the testing and maintenance practices of
 a **Requester** when the **End-User's** system is operated as a network with the Hoosier
 Energy transmission system.

24.0 COORDINATION WITH OTHER CODES, STANDARDS, AND AGENCIES

The information contained in this document is supplementary to and does not intentionally conflict with or supersede the National Electric Code (NEC) as approved by the American National Standards Institute (ANSI) or such federal, state and municipal laws, ordinances, rules or regulations as may be in force within the cities, towns or communities in which Hoosier Energy furnishes electric service. It is the responsibility of the **Transmission Interconnection** or **End-User** to conform to all applicable national, state and local laws, ordinances, rules, regulations, codes, etc.

813 **25.0 INDEMNIFICATION**

The use and reliance upon the information contained in this document shall in no way relieve the **Transmission Interconnection** or **End-User** from the responsibility to meet NEC, IEEE, and NESC requirements governing their design, construction, operation, and materials.

The **Requester**, for itself, its successors, assigns and subcontractors will be required to pay, indemnify and save Hoosier Energy, its successors and assigns, harmless from

820 and against any and all court costs and litigation expenses, including legal fees, incurred

RURAL ELECTRIC COOPERATIVE, INC.	Transmission and End-User	Effective Date: 1-12-24
	Interconnection Requirements	Version: 8

821 or related to the defense of any action asserted by any person or persons for bodily 822 injuries, death or property damage arising or in any manner growing out of the use and 823 reliance upon the information provided by Hoosier Energy. Reliance upon the 824 information in this document shall not relieve the **Transmission Interconnection** or

End-User from responsibility for the protection and safety of the general public.

84/

HOOSIERENERGY
RURAL ELECTRIC COOPERATIVE, INC.Transmission and End-UserEffective Date: 1-12-24Interconnection RequirementsVersion: 8

849 ATTACHMENT A: TYPICAL END-USER INTERCONNECTION





858 ATTACHMENT B: TYPICAL TRANSMISSION INTERCONNECTION

859



860 861 862



OR





ATTACHMENT C: VOLTAGE FLICKER CRITERIA AND HARMMONIC DISTORATION CRITERIA SUMMARY

This attachment summarizes Hoosier Energy's policy on voltage flicker and harmonic distortion for customers connected to the electrical system via a Company dedicated transformer or a Customer owned transformer. The term Company is defined as Hoosier Energy REC, Inc. The term Customer is defined as the party connected to the Hoosier Energy System.

I. POINT OF COMPLIANCE -The point where the Company dedicated transformer or Customer owned transformer connects to the Company system will be the point where compliance with the voltage flicker and harmonic distortion requirements are evaluated.

876 II. VOLTAGE FLICKER CRITERIA -The Company requires that the voltage flicker
 877 occurring at the point of compliance shall remain below the Border Line of Visibility curve
 878 on the IEEE/GE curve for fluctuations less than I per second or greater than 10 per
 879 second (see Exhibit 1). In the range of 1 to 10 fluctuations per second, the voltage flicker
 880 shall remain below 0.4%.

The Customer agrees that under no circumstances will it permit the voltage flicker to exceed the Company criteria, whether or not complaints are received or service/operational problems are experienced on the Company subtransmission or transmission system. Should complaints be received by the Company or other operating problems arise, or should the Customer flicker exceed the borderline of visibility curve, the Customer agrees to take immediate action to reduce its flicker to a level at which flicker complaints and service/operational problems are eliminated.

888 Corrective measures could include, but are not limited to, modifying production methods/ 889 materials or installing, at the Customer's expense, voltage flicker mitigation equipment 890 such as a static var compensator. The Company will work collaboratively with the 891 Customer to assess problems, identify solutions and implement mutually agreed to 892 corrective measures.

893 If the Customer fails to take corrective action after notice by the Company, the Company 894 shall have such rights as currently provided for under its tariffs, which may include 895 discontinuing service, until such time as the problem is corrected.

III. HARMONIC DISTORTION CRITERIA -The Company also requires that the
 Customer's operation be in compliance with the Company's Harmonic Distortion
 Guidelines (see Exhibit 2). These requirements are based on IEEE Standard 519, "IEEE
 Recommended Practices and Requirements for Harmonic Control in Electric Power
 Systems".

901 The Customer agrees that the operation of motors, appliances, devices or apparatus 902 served by its system and resulting in harmonic distortions in excess of the Company's 903 Requirements will be the Customer's responsibility to take immediate action, at the

HOOSIERENERGY	Transmission and End-User	Effective Date: 1-12-24
RURAL ELECTRIC COOPERATIVE, INC.	Interconnection Requirements	Version: 8

904 Customer's expense, to comply with the Company's Harmonic Distortion Requirements. 905 The Company will work collaboratively with the Customer to assess problems, identify 906 solutions and implement mutually agreed to corrective measures. If the Customer fails 907 to take corrective action after notice by the Company, the Company shall have such 908 rights as currently provided for under its tariffs, which may include discontinuing service, 909 until such time as the problem is corrected.



930

931

EXHIBIT 1 RELATIONS OF VOLTAGE FLUCTUATIONS TO FREQUENCY OF THEIR OCCURANCE



HOOSIERENERGY	Transmission and End-User	Effective Date: 1-12-24
RURAL ELECTRIC COOPERATIVE, INC.	Interconnection Requirements	Version: 8

952

EXHIBIT 2 HARMONIC DISTORTION REQUIREMENTS

953 The Hoosier Energy Harmonic Distortion Requirements shown below are based on the information I_L presented in the IEEE Standard 519, approved in 1992 and titled. 954 "IEEE Recommended Practices and Requirements for Harmonic Control in Electric 955 Power Systems." The voltage limits are intended to be used to gauge the 956 957 acceptability of harmonic magnitudes on the transmission systems, while the current 958 limits are applicable to individual customers injecting harmonic currents at the point of common coupling (FCC). 959

	Individual Harmonic	Total Voltage Distortion THD_v (%)
Bus Voltage at PCC	Voltage Distortion (%)	
<u><</u> 69kV	3.0	5.0
69kV <v<u><161kV</v<u>	1.5	2.5
Above 161 kV	1.0	1.5

HARMONIC VOLTAGE DISTORTION (THD_v) LIMITS

	HARMON	IC CURRENT	DEMAND DIS	STORTION (T	DD) LIMITS	5
MAX	MAXIMUM HARMONIC CURRENT DISTORTION IN % OF BASE QUANTITY					
		Harmonic	Order (Odd	Harmonics)		
			v ≤ 69 kV			
I _{SC} /I L	< 11	11 ≤ h < 17	17 ≤ h <	23≤ h<35	35 ≤ h	TDD
<20	4.0	2.0	1.5	0.5	0.3	5.0
20-50	7.0	3.5	2.5	1.0	0.5	8.0
50-100	10.0	4.5	4.0	1.5	0.7	12.0
100-1000	12.0	5.5	5.0	2.0	1.0	15.0
>1000	15.0	7.0	6.0	2.5	1.4	20.0
		1		1		I
		69	kV < v ≤ 161	kV		
			kV			
< 20*	2.0	1.0	0.75	0.3	0.15	2.5
20-50	3.5	1.75	1.25	0.5	0.25	4.0
50-100	5.0	2.25	2.0	0.75	0.35	6.0
100-1000	6.0	2.75	2.5	1.0	0.5	7.5
>1000	7.5	3.5	3.0	1.25	0.7	10.0
			161 kV <v< td=""><td></td><td></td><td></td></v<>			
<50	2.0	1.0	0.75	0.3	0.15	2.5
≥50	3.0	1.5	1.15	0.45	0.22	3.75
Whore L Maxi	mum chart	circuit at DC	r			

= Maximum short circuit at PCC

 I_L = Load current at the time of the maximum metered amount

*All power generation equipment is limited to these values of current distortion, regardless of actual I_{sc} / I_{L} .

Even harmonics are limited to 25% of the odd harmonic limits above.



EXHIBIT 3 HARMONIC DISTORTION CALCULATIONS

963 Harmonic Voltage Distortion is to be normalized to the nominal system voltage964 and calculated using Equation 1.

965

961 962

TOTAL VOLTAGE HARMONIC DISTORTION (THD_v) in percent:

$$THD_{v} = \frac{\sqrt{\sum_{n=2}^{v} V_{n}^{2}}}{V_{s}} \times 100\% \qquad (Eq.1)$$

- 966 Where:
- 967 V_n = Magnitude at Individual Harmonics (RMS)
- 968 V_s = Nominal System Voltage (RMS)

969 n = Number of Harmonic Order

Harmonic Current Distortion is to be normalized to the customer's load current at
 the time of the maximum metered demand which occurred over the preceding twelve

972 months for existing customers and the customers anticipated peak demand for new

973 customers. For existing customers who are increasing their load, the projected
 974 demand should be used. The harmonic current demand distortion (TDD) should be

975 calculated using Equation 2.

976

TOTAL CURRENT DEMAND DISTORTION (TDD) in percent:

$$TDD = \frac{\sqrt{\sum_{n=2}^{\infty} I_n^2}}{I_L} \times 100\% \quad (Eq.2)$$

- 977 Where:
- I_n = magnitude of Individual Harmonic (RMS)
- I_{L} = Load Current at the Time of the Maximum Metered Demand
- 980 n = Harmonic Order

981 PCC - Point of Common Coupling- The location where the customer accepts
 982 delivery of electrical energy from the utility.

Field Measurements- To gauge the acceptability of field measured harmonic
distortion, a statistical evaluation of the data is to be performed. Measurements
should be taken at live minute intervals or less over a minimum of 24 hours. For the
measured data to be considered acceptable, two criteria must be met: 1) 95% of the
measured data must fall below the limits stated; 2) no measured data shall exceed
the limits specified by more than 50% of the absolute upper limit value.

989



991

992

EXHIBIT 4 HARMONIC INFLUENCE

As stated in IEEE Standard 519, it is difficult to place specific limits on the telephone influence which the harmonic components of current and voltage can inflict. Hence, IEEE Standard 519 outlines a range of values where problems could our (refer 10 the table below). The actual interference to voice communication systems in proximity to the power system is dependent upon a number of factors not under the control of the utility or customer, these factors will vary from location to location and from time to time as the state-of-the-art of inductive coordination progresses.

	IEEE Standard 519 - Balanced I*T Guidelin	es
Category	Description	I*T
I	Levels most unlikely to cause interference	<10,000
II	Levels that might cause interference	10,000 to 25,000
II	Levels that probably will cause interference	> 50,000

1000 The limit applicable to Hoosier Energy is the upper bound limit of the I*T levels that might cause interference on telephone systems. Thus, the customer induced harmonics 1001 1002 shall not result in an I*T product to exceed 25,000 weighted amperes per phase, 1003 applicable to both the transmission and distribution systems. Residual I*T should also be minimized. Residual I*T is IG*T, where IG is the earth return current and is defined as 1004 the difference between the phasor sum of phase currents and neutral current. The I*T 1005 1006 calculation is to be performed using Equation 3. The weighting of harmonic currents should conform to the 1960 TIF curve shown below. 1007

 $I^*T = I^*TIF = \sqrt{\sum_{n=1}^{K} (I_n * W_n)^2} \qquad w$

weighted amperes(Eq.3)

1009 1010 Where:

1010	
1011	I = Current of individual harmonics, amperes, RMS
1012	T = Telephone Influence Factor (TIF)
1013	W_n = Single frequency TIF weighting at frequency n (refer to table and chart below)

- 1014 K < 42, Maximum harmonic order
- 1015
- 1016
- 1017
- 1018
- 1019
- V ± J
- 1020

HOOSIERENERGY	Transmission and End-User	Effective Date: 1-12-24
RURAL ELECTRIC COOPERATIVE, INC.	Interconnection Requirements	Version: 8

FREQ	TIF (\w/)	FREQ	TIF (\w/)	FREQ	TIF (\w/)	FREQ	TIF (\w/)
60	0.5	1020	5100	1860	7820	3000	9670
180	30	1080	5400	1980	8330	3180	8740
300	225	1140	5630	2100	8830	3300	8090
360	400	1260	6050	2160	9080	3540	6730
420	650	1380	6370	2220	9330	3660	6130
540	1320	1440	5650	2340	9840	3900	4400
660	2260	1500	6680	2460	10340	4020	3700
720•	2760	1620	6970	2580	10600	4260	2750
780	3360	1740	7320	2820	10210	4380	2190
900	4350	1800	7570	2940	9820	5000	840
1000	5000						

ATTACHMENT D: ELECTRICAL CLEARANCES AND EQUIPMENT 1023 RATINGS 1024

1025

1026

ELECTRICAL CLEARANCES

	Basic In Insula Lev	npulse ation vel	Outdoor Design Clearance (in.)		Air Insulated Switch Design Clearance (in.)				
	(BIL)	(KV crest) (2)					Air Break	Disconn ect	
	Bus &	Vfmr	Cente	rline-	Center	line-	Dhaaa	Dhass	
	Xfmr		Gro	und	Centei	rline	Phase	Phase	Station Post
Nominal	Winding	Busning	Rigid	Strain	Rigid Bus	Strain	Spacing	Spacing	Insulators
System			Bus	Bus		Bus			Technical
Voltage									Reference
(kV)									Number(1)(2)
765	2050	2050	195	240	390	480	480	390	n/a
500	1550	1550	147	180	270	300	300	270	379
345	1050	1050	99	132	150	180	216	150	316
230	900	900	84	120	124	164	192	124	304,308
161	750	750	63	86	86	116	168	86	291,295
138	550	650	46	60	72	84	144	72	286,287
88	450	550	37	44	54	60	108	54	286,287
69	350	350	29	36	42	48	84	42	216
46	250	250	21	24	36	42	72	36	214
34.5	200	200	16	21	30	36	60	30	210
23	150	200	13	18	24	30	60	30	208

1027 1028

- 1029 1030
- 1031
- 1032 1033
- 1034

1035

1036

1037

series for post type insulators and are the Hoosier Energy standard for the voltage class. Refer to ANSI Standard C29.9-1983(R2012), Table 1, for dimensions and characteristics for each insulator. Higher strength insulators with different technical reference numbers are available and should be used if required. The ANSI Technical Reference (T.R.) numbers refer to insulators with specific mechanical ratings. Higher ratings may be required or may be adequate according to the duty of the specific application.

(1) The technical reference numbers shown are a widely used identification

(2) Substations in heavily contaminated areas may require a higher insulation level than indicated.



1038 ATTACHMENT E PROTECTIVE LOOP INSTALLATION

- 1039
- 1039
- 1040
- 1041

PROTECTIVE LOOP INSTALLATION for various line conditions

Air Break Switch on a Line	Wood Pole Line Direct Embedded Steel Pole Self Supported Steel Pole
1. With shield wires grounded at every structure and extending for at least ½ mile in both directions from the air break switch location.	Grounding Protection Loop Fig. 1
2. With ungrounded shield wires extending for at least ½ mile in both directions from the air break switch location.	Grounding Protection Loop Fig. 2
3. With air break switch ground bonded to multi-grounded neutral or to nearby station ground grid.	Grounding Protection Loop Fig. 1
4. With no shield wire or shield wire extending less than ½ mile in both directions, with no multi-grounded neutral and with air break switch not bonded to nearby station ground grid.	Grounding Protection Loop Fig. 2

1042 **Design Limits**:

1043

1046

1048

- 1044 **ΙΦ-Gnd = 8000A Max**.
- 1045 Soil Resistivity = 500 Ω -Meter Max.
 - (If exceeded further analysis is required)
- 1047 Spread 3/4" crushed stone with 10-15% binding material,
 - 4" deep over entire area extending 1'-0" beyond grounding

1049 NOTES FOR FIGURE 1 & 2

- A.) For wood pole structures, a minimum 8 foot length of wood or plastic
 protective molding should be installed to completely cover the 4/0 AWG
 copper ground wire.
- B.) Tie protective grounding loop to 4/0 AWG copper ground wire (Wood Pole)
 or structure ground pad (Steel Pole). In either case, the switch handle
 ground must be terminated to this 4/0 AWG copper ground wire.

1056 1057	C.) If switch structure is 100 feet or less from existing station ground grid, guy wire anchor grounding is recommended. Also, connect protective ground
1058	loop to existing station ground grid as noted.
1059	
1060	
1061	
1062	
1063	
1064	
1065	
1066	
1067	
1068	
1069	
1070	
1071	
1072	
1073	
1074	
1075	
1076	
1077	
1078	
1079	
1080	
1081	
1082	
1083	
1084	
1085	
1086	
1087	
1088	
1089	
1090	
1091	
1092	
1093	
1094	
1095	
1096	
1097	
1098	
1099	
1100	
1101	



FIGURE 1





HOOSIER ENERG	Y
RURAL ELECTRIC COOPERATIVE, IN	ċ.



HOOSIERENERGY RURAL ELECTRIC COOPERATIVE, INC.

1143	ļ	ATTACHMENT F: TURNOVER	INSPECTION REQUIR	EMENTS FORM
1144 1145		CONNE	CTINC FACILITY	
1146		CONNE	CTING FACILIT I	
1147		Electrical Facility Chec	ekout Guide (Turnover Inspecti	ion)
1148		ITEM AC	TION/INFORMATION BY	DATE
1149	1.	Facility Ground Resistance	Review Test Results	
1150	2.	Air break and Disconnect Switch Alignment	:	
1151 1152 1153 1154 1155 1156		a. <u>Switch Device Number</u> b. <u>Switch Device Number</u> c. <u>Switch Device Number</u> d. <u>Switch Device Number</u> e. <u>Switch Device Number</u> f. <u>Switch Device Number</u>	Visual Inspection	
1157	3.	Circuit Breakers		
1158		a. kV Circuit Breaker <u>Device Number</u>		
1159 1160 1161 1162 1163 1164		 Gas Filled Timing Tests Digital Low R Ohmmeter Doble Test CT Ratio & Polarity Breaker Alarms 	Visual Inspection Review Test Results Review Test Results Review Test Results Review Test Results Detailed Inspection	
1165	4.	Circuit Switcher		
1166		akV Circuit Breaker <u>Device Nu</u>	<u>mber</u>	
1167 1168 1169		 Hipot Test Timing Test Digital Low R Ohmmeter 	Review Test Results Review Test Results Review Test Results	
1170	5.	Fuses		
1171		akV Fuses <u>Device Number</u>		
1172 1173		 Rating/Type Air Flow Test 	Visual Inspection Review Test Results	
1174	6.	Power Transformer		
1175		akV Transformer <u>Device Numb</u>	<u>er</u>	
1176		1. CT Ratio & Polarity	Review Test Results	<u> </u>

RURAL ELECTRIC COOPERATIVE, INC.

Transmission and End-User Interconnection Requirements

1177	7. CCVT	V/VT		
1178		a. <u>kV <i>Circuit/Line Name</i></u> CCVT/	NT <u>Device Number</u>	
1179 1180 1181		1. Doble Test 2. Potential Polarizing Test 3. Ratio & Polarity Test	Review Test Results Review Test Results Review Test Results	
1182		bkV CCVT/VT <u>Device Number</u>		
1183 1184 1185		 Doble Test Potential Polarizing Test Ratio & Polarity Test 	Review Test Results Review Test Results Review Test Results	
1186	8. Phasin	g		
1187		akV BUS <u>Number</u>	Detailed Inspection	
1188	9. Batter	ies and Charger		
1189		aV DC Battery and Charger		
1190 1191 1192 1193		 Battery Acceptable Intercell Resistance Test Charger Settings Ground Detector 	Review Test Results Review Test Results Visual Inspection Detailed Inspection	
1194	10. SCAD	Α		
1195		a. Function Test with SCC		
1196 1197 1198		 Control Indication Alarms 	Detailed Inspection Detailed Inspection Detailed Inspection	
1199		b. Metering	Detailed Inspection	
1200	11. Relay	and Control Schematics		
1201		akV Circuit Breaker <u>Device Nur</u>	<u>nber</u>	
1202 1203 1204 1205 1206 1207		 Correct Settings Applied Calibration Test Trip Test In-Service Load Angles Remote Relay Communication 	Review Test Results Review Test Results Detailed Inspection Detailed Inspection Detailed Inspection	
1208		bAnnunicators and Alarms		
1209 1210		 Set Undervoltage & Time Delay Relays 	Review Test Results	

	Η	1005	SIE	REN	JERGY	Transr	missior	n and End-l	Jser	Effect	ive Date: 1	-12-24
	RU	IRAL ELEC	TRIC	COOPER	RATIVE, INC.	Interco	onnect	ion Requir	ements	Versic	on: 8	
211				2.	Function Te	sted	I	Review Test F	Results			
212	12.	Miscel	lane	ous								
213			a.	Arresto	ors							
214 215				1. 2.	Sized Corr Located Pr	ectly operly	\ \	/isual Inspe /isual Inspe	ction ction			
216			b.	Clearar	nce							
217 218 219 220				1. 2. 3.	Bus to Gro Bus to Bus Bus to Stee	und el		/isual Inspec /isual Inspec /isual Inspec	ction ction ction			
221												
222												
224												
225												
226												
227												
228												
229												
230												
231												
232												
.233												
234												
233												
230												
238												
239												
240												
241												
242												
243												
244												
245												
246												
247												
248												

HOOSIERENERGY	Transmission and End-User	Effective Date: 1-12-24		
RURAL ELECTRIC COOPERATIVE, INC.	Interconnection Requirements	Version: 8		

1249 26.0 APPROVALS

APPROVAL:	DATE
Manager, System Planning	
Carl Field Carl Field (Jan 11, 2024 10:45 EST)	Jan 11, 2024
Carl Field	

Transmission_End-User Interconnection Requirements_V8

Final Audit Report

2024-01-11

Created:	2024-01-11
By:	Michael Dicks (mdicks@hepn.com)
Status:	Signed
Transaction ID:	CBJCHBCAABAAcRc1QKFGEjGhlX7NyYLE4qUac9E1kFu-

"Transmission_End-User Interconnection Requirements_V8" His tory

- Document created by Michael Dicks (mdicks@hepn.com) 2024-01-11 - 3:27:35 PM GMT
- Document emailed to Carl Field (cfield@hepn.com) for signature 2024-01-11 - 3:28:25 PM GMT
- Email viewed by Carl Field (cfield@hepn.com) 2024-01-11 - 3:28:45 PM GMT
- Document e-signed by Carl Field (cfield@hepn.com) Signature Date: 2024-01-11 - 3:45:44 PM GMT - Time Source: server
- Agreement completed. 2024-01-11 - 3:45:44 PM GMT